

Systemy zabezpieczeń przeciwpożarowych Fire protection systems

"MERCOR" S.A.

ul. Grzegorza z Sanoka 2, 80-408 GDAŃSK, Polska tel. (+48 58) 341 42 45, fax (+48 58) 341 39 85 e-mail: mercor@mercor.com.pl www.mercor.com.pl

DECLARATION OF PERFORMANCE NO. 002-01-CPD-2017

1. Product name:

Powered smoke and heat exhaust radial ventilators type mcr PASAT.

2. Unique identification code of the product-type:

A unique serial No. of each fan is provided on the label.

3. Intended use and scope of application of the product:

Powered smoke and heat exhaust radial ventilators of resistance class F₄₀₀120, designed to operate as one or two speed fans in order to remove hot air, smoke and exhaust fumes created in premises during a fire and within general ventilation systems.

4. Manufacturer:

MERCOR SA, ul. Grzegorza z Sanoka 2, 80-408 Gdańsk, Zakład Produkcyjny [Production Site], ul. Kwarcowa 3a, Cieplewo.

- System of assessment and verification of constancy of performance of the product: System 1
- Construction product covered by the harmonised standard: EN 12101-3:2002+AC:2005
- Notified body name and No., certificate of conformity No.: Notified Body No. 1488, ITB, ul. Filtrowa 1, 00-611 Warszawa CE Certificate of Conformity: 1488-CPD-0209/W

8. Declared performance:

| NO. | Essential characteristics of the product | Harmonised standard EN 12101-3:2002+AC:2005 | Mandated levels and/or classes | Scope of essential characteristics regarding intended use of product |
|---|--|---|--------------------------------|---|
| | | | | |
| fire conditions Resistance to fire: - Smoke leakage | 6.1.2 | | | |
| - Mechanical stability | | | | |

Declared intended use of product: Bifunctional device of fire protection for extraction of smoke and hot gases which operates in general ventilation and during fire.

| Classes of usage: | | | | |
|---|-------------------|--|--|--|
| Insulation | non-insulated | | | |
| Operation inside smoke container | unadapted | | | |
| Functionality | mono/dual-purpose | | | |
| Cooling with air brought by duct system | yes | | | |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

mercor

Gdańsk, 23.10.2017

Robert Skomra

DYREKTOR ZAKŁADU

Robert Skomra

Rev. 1





