

DECLARATION OF PERFORMANCE NR 005-00-CPR-2014

1. **Unique identification code of the product type:**
Device for mechanical extraction of smoke and heat control systems (axial fan) mcr Monsun C and mcr Monsun C/ATEX, classification according to EN 13501-4:2016
F₄₀₀120
2. **Type, batch or serial No.:**
A unique serial No. of each fan is provided on the label.
3. **Intended use / uses:**
Axial smoke fans, designed to operate as one or two speed fans in order to remove hot air, smoke and exhaust fumes created in premises during a fire.
4. **Manufacturer:**
“MERCOR” SA, ul. Grzegorza z Sanoka 2, 80-408 Gdańsk, Production plant: 16/32301598.
5. **System of assessment and verification of constancy of performance of the product:**
System 1.
6. **Construction product covered by the harmonised standard:**
EN 12101-3:2015.
7. **Notified body name and No., certificate of conformity No.:**
Notified Body No. 0370, LGAI Technological Center, S.A. (APPLUS)
Certificate of Constancy of Performance: 0370-CPR-1934.
8. **Declared performance:**

No.	Essential characteristics	Standard	Performance
		EN 12101-3	
1	Response delay:		
	- opening under wind load within a given time	4.1.1	NPD
	- opening under snow load within a given time	4.1.1	SL0
2	Operational reliability:		
	- application categories	4.2.2	Thermally uninsulated Installation outside the smoke reservoir Horizontal position work Direct feed Dual purpose use
	- motor rating	4.2.3	NPD
3	Effectiveness of smoke/ hot gas extraction:		
	- gas flow and pressure maintenance during smoke and heat extraction test	4.3.2	Pass
4	Resistance to fire	4.4	F ₄₀₀ 120
5	Ability to open under environmental conditions:		
	- opening under wind load within a given time	4.5	NPD
	- opening under snow load within a given time		SL0
6	Durability of operational reliability		NPD

DWU_005-00-CPR-2014_Monsun_C_EN_20221212 1/2

Systemy zabezpieczeń przeciwpożarowych
Fire protection systems

„MERCOR” S.A.

ul. Grzegorza z Sanoka 2, 80-408 GDAŃSK, Polska
tel. (+48 58) 341 42 45, fax (+48 58) 341 39 85
e-mail: mercor@mercort.com.pl
www.mercort.com.pl

9. Additional properties:

The fan can cooperate with additional equipment:

- External connection box,
- Service switches

The performance of the product identified above is in conformity with the set of declared performance/s (point 8). This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Gdańsk, 2022-12-12



mercor
Tomasz Kobyliński
KIEROWNIK ZAKŁADU PRODUKCJI
SYSTEMÓW WENTYLACJI POŻAROWEJ

Tomasz Kobyliński

Rev. 3