



Reg. No. 041/P-007

NOTIFIED BODY No. 1396  
Osloboditeľov 282, 059 35 Batizovce, Slovakia  
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



## Certificate of constancy of performance

**1396 – CPR – 0032**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Natural smoke and heat exhaust ventilator louver-type MCR LAM

having the performances and used in conditions given by initial type testing report No. C1396/08/0042/5003/SC issued by FIRES, s.r.o., NB 1396, Slovakia, on 26. 05. 2009,  
produced by

**MERCOR SA**  
**ul. Grzegorza z Sanoka 2, 80-408 Gdansk, Poland**

and produced in the manufacturing plant

**MERCOR SA**  
**Zakład Produkcyjny, ul. Kwarцова 3A, Ciepłewo, 83-031 Łęgowo**  
**Poland**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 12101-2: 2003**

under system 1 for the performances set out in this certificate are applied and that  
**the construction product fulfils all the prescribed requirements for these performances.**

This certificate was first issued on 26. 05. 2009 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Batizovce, 14. 11. 2014



*Ing. Mária Gašperová*  
Ing. Mária Gašperová  
Head of Product Certification Body

064273 FIRES 136a/C-29/07/2014-E