



Reg. No. 041/P-007

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



Certificate of constancy of performance

1396 - CPR – 0040

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

NATURAL SMOKE AND HEAT EXHAUST VENTILATOR, TYPE MCR PROLIGHT

used either as a dual purpose ventilator or only as a smoke and heat exhaust ventilator without daily ventilation, with properties and used on conditions as described in Initial type-testing report No. C1396/10/0011/4203/SC issued by FIRES, s.r.o., Notified Body 1396 on 22. 06. 2010 amended by an actual report of continuous surveillance,

produced by

MERCOR SA

ul. Grzegorza z Sanoka 2, 80-408 Gdańsk, Poland

and produced in the manufacturing plant

MERCOR SA

**Zakład Produkcyjny, ul. Kwarцова 3A, Ciepłowo,
83 031 Łęgowo, Poland**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 12101 - 2: 2003

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 22th June 2010 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Batizovce, 20. 05. 2014



Ing. Mária Gašperová
Ing. Mária Gašperová
Head of Certification body

064202

FIRES 136a/C-12/12/2013-E